

**Table 3-1 - Pleasant Ridge Sound Analysis MAXIMUM Octave Bands Results Summary (GE 1.79-100 Turbine Model)  
11 LNTE Turbines and Substation (500 and 1,000 Hz Bands)**

<i>With Substation</i>										
<i>All Values in dB</i>	<b>Octave Band Center Frequency</b>	<b>31.5 Hz</b>	<b>62.5 Hz</b>	<b>125 Hz</b>	<b>250 Hz</b>	<b>500 Hz</b>	<b>1000 Hz</b>	<b>2000 Hz</b>	<b>4000 Hz</b>	<b>8000 Hz</b>
<b>IPCB Daytime</b>		<b>75.0</b>	<b>74.0</b>	<b>69.0</b>	<b>64.0</b>	<b>58.0</b>	<b>52.0</b>	<b>47.0</b>	<b>43.0</b>	<b>40.0</b>
<b>IPCB Nighttime</b>		<b>69.0</b>	<b>67.0</b>	<b>62.0</b>	<b>54.0</b>	<b>47.0</b>	<b>41.0</b>	<b>36.0</b>	<b>32.0</b>	<b>32.0</b>
<b>Max Sound-dBA (Std Blade)</b>		<b>81.1</b>	<b>90.8</b>	<b>95.7</b>	<b>98.3</b>	<b>102.0</b>	<b>102.9</b>	<b>99.5</b>	<b>91.9</b>	<b>72.9</b>
<b>Max Sound dBA (LNTE Blade)</b>		<b>81.0</b>	<b>90.6</b>	<b>94.5</b>	<b>95.3</b>	<b>97.6</b>	<b>100.6</b>	<b>99.6</b>	<b>92.7</b>	<b>73.7</b>
<b>Reference ID</b>	<b>Participation Status and Results</b>									
R-005	Non-Participant	63.6	59.8	54.0	48.1	45.4	41.2	31.5	6.3	-75.2
R-006	Non-Participant	63.3	59.5	53.5	47.5	44.5	40.4	31.2	9.4	-58.9
R-007	Non-Participant	63.3	59.4	53.4	47.2	44.0	39.3	28.3	-0.8	-94.1
R-008	Non-Participant	63.4	59.5	53.5	47.4	44.2	39.7	29.6	5.9	-68.5
R-009	Non-Participant	63.5	59.6	53.6	47.3	43.9	39.0	27.1	-4.4	-104.1
R-010	Non-Participant	63.6	59.7	53.6	47.4	44.1	39.3	27.6	-2.8	-98.7
R-011	Participant	63.8	59.9	53.9	47.8	44.7	40.3	29.9	4.4	-76.9
R-012	Non-Participant	63.8	59.9	53.9	47.7	44.6	40.5	30.9	4.9	-78.8
R-013	Participant	64.3	60.4	54.4	48.1	45.0	41.3	32.9	11.6	-57.8
R-014	Participant	63.9	60.0	53.9	47.7	44.5	40.4	31.1	5.6	-78.4
R-021	Non-Participant	63.4	59.6	53.6	47.5	44.4	39.9	29.8	6.5	-66.6
R-022	Participant	64.0	60.2	54.3	48.4	45.5	41.3	31.7	9.0	-60.8
R-023	Participant	63.2	59.4	53.4	47.2	44.0	39.4	29.1	5.0	-70.7
R-027	Non-Participant	62.7	58.8	53.2	47.1	44.4	39.7	29.8	6.8	-55.8
R-028	Participant	63.2	59.3	53.5	47.8	45.2	41.4	33.0	13.0	-49.7
R-038	Non-Participant	63.3	59.4	53.6	47.7	44.9	40.7	30.9	6.4	-72.3
R-039	Non-Participant	62.9	59.0	53.1	47.3	44.5	40.5	31.1	7.1	-71.1
R-041	Non-Participant	59.9	55.9	49.5	42.8	39.3	34.0	21.7	-10.8	-117.4
R-043	Non-Participant	60.9	57.0	50.9	44.9	42.1	38.3	30.0	9.7	-57.0
R-059	Participant	62.8	58.9	53.1	46.6	43.4	39.1	29.1	2.2	-85.3
R-060	Participant	63.6	59.7	53.7	47.6	44.6	41.0	32.8	12.0	-55.0
R-063	Non-Participant	62.8	58.9	52.9	46.8	43.8	39.4	29.7	6.6	-66.0
R-085	Non-Participant	62.9	59.0	52.9	46.8	43.7	39.6	30.0	7.0	-65.1
R-091	Participant	64.1	60.3	54.2	47.9	44.8	40.7	31.5	8.5	-63.8
R-092	Non-Participant	64.1	60.3	54.5	48.4	45.5	41.2	31.5	6.2	-71.8
R-093	Participant	62.9	59.0	53.1	47.1	44.1	39.8	29.6	4.3	-77.9
R-099	Non-Participant	63.3	59.4	53.3	46.9	43.6	39.1	28.6	3.2	-75.8
R-100	Non-Participant	63.2	59.3	53.2	47.0	43.8	39.4	29.5	6.9	-64.9
R-101	Non-Participant	63.4	59.5	53.4	47.0	43.7	39.5	29.9	4.9	-77.3
R-102	Non-Participant	63.7	59.8	53.9	47.8	44.8	40.8	31.8	9.7	-62.1
R-122	Participant	62.5	58.6	52.7	46.8	43.8	39.5	29.1	2.4	-84.1
R-142	Non-Participant	63.4	59.5	53.4	47.1	43.8	39.4	29.2	4.3	-73.0
R-160	Non-Participant	63.0	59.2	53.2	47.3	44.4	40.1	30.4	6.9	-65.8
R-166	Non-Participant	63.2	59.3	53.6	47.8	45.0	40.9	31.2	6.7	-72.2
R-168	Non-Participant	62.9	59.0	53.2	47.3	44.5	40.5	31.3	9.3	-60.3
R-169	Non-Participant	62.1	58.2	52.3	46.4	43.6	39.6	31.1	11.0	-53.8
R-183	Participant	62.7	58.8	52.8	46.8	43.9	39.8	30.7	9.9	-56.6
R-185	Participant	64.4	60.6	54.6	48.4	45.3	41.1	31.1	5.4	-74.9
R-186	Non-Participant	64.2	60.3	54.3	47.9	44.6	40.3	30.0	2.9	-83.5
R-187	Non-Participant	63.5	59.6	53.6	47.4	44.1	39.4	28.5	2.0	-79.8
R-191	Participant	63.4	59.5	53.5	47.4	44.5	40.5	31.6	9.7	-60.3
R-210	Non-Participant	62.9	59.1	53.2	47.2	44.2	39.8	29.4	3.3	-77.8
R-216	Non-Participant	62.6	58.7	52.7	46.6	43.9	40.8	33.2	12.2	-57.1
R-217	Participant	61.9	58.0	52.2	46.0	43.3	39.9	31.9	11.8	-51.8
R-221	Participant	63.1	59.2	53.4	47.5	44.7	40.5	30.9	7.9	-63.3
R-222	Non-Participant	63.1	59.3	53.4	47.5	44.7	40.4	30.7	8.0	-62.4
R-236	Non-Participant	62.9	59.0	53.2	47.3	44.4	40.3	31.5	12.0	-50.9
R-237	Participant	63.3	59.5	53.7	47.9	45.2	41.3	32.7	13.1	-48.4
R-239	Non-Participant	63.6	59.7	53.8	47.7	44.8	40.6	30.6	6.1	-68.6
R-240	Participant	63.6	59.8	53.8	47.7	44.7	40.6	30.9	8.0	-62.3
R-241	Non-Participant	63.8	59.9	53.9	47.6	44.4	40.6	31.7	8.5	-65.2
R-242	Non-Participant	63.6	59.7	53.6	47.3	44.0	40.0	30.3	4.3	-77.1
R-243	Non-Participant	63.7	59.9	53.9	47.9	45.0	41.1	32.0	9.4	-60.9
R-244	Participant	63.9	60.0	54.0	47.9	44.8	41.0	31.9	7.8	-70.4
R-270	Non-Participant	63.4	59.5	53.7	47.9	45.1	41.1	31.5	7.0	-68.9
R-311	Non-Participant	63.8	60.0	54.0	48.0	45.0	40.9	31.5	8.0	-68.5
R-313	Non-Participant	64.1	60.3	54.2	48.0	44.9	41.0	32.0	8.8	-65.6
R-314	Participant	64.1	60.3	54.4	48.3	45.4	41.1	31.3	5.4	-76.5
R-317	Non-Participant	63.7	59.8	53.7	47.2	43.7	39.5	29.9	5.1	-73.5

**Table 3-1 - Pleasant Ridge Sound Analysis MAXIMUM Octave Bands Results Summary (GE 1.79-100 Turbine Model)  
11 LNTE Turbines and Substation (500 and 1,000 Hz Bands)**

<i>With Substation</i>										
<i>All Values in dB</i>	<b>Octave Band Center Frequency</b>	<b>31.5 Hz</b>	<b>62.5 Hz</b>	<b>125 Hz</b>	<b>250 Hz</b>	<b>500 Hz</b>	<b>1000 Hz</b>	<b>2000 Hz</b>	<b>4000 Hz</b>	<b>8000 Hz</b>
R-318	Non-Participant	63.3	59.4	53.3	47.0	43.7	39.2	28.5	2.3	-78.5
R-319	Non-Participant	63.5	59.6	53.6	47.3	44.0	39.5	29.1	1.6	-85.4
R-321	Non-Participant	63.3	59.4	53.5	47.5	44.6	40.7	31.8	10.2	-59.1
R-324	Participant	63.7	59.8	53.8	47.5	44.4	40.3	30.7	6.3	-68.7
R-326	Non-Participant	63.2	59.3	53.1	46.5	43.0	39.0	30.2	6.3	-69.9
R-327	Participant	64.1	60.2	54.2	48.1	45.0	40.8	31.0	5.8	-76.0
R-329	Non-Participant	64.5	60.6	54.4	48.0	44.6	41.1	33.7	14.2	-48.7
R-345	Non-Participant	64.0	60.1	54.3	48.3	45.5	41.3	31.8	8.8	-62.1
R-354	Participant	63.0	59.1	53.2	47.3	44.4	40.5	31.8	12.0	-51.1
R-355	Non-Participant	62.7	58.8	52.8	46.8	43.8	39.6	29.7	4.6	-76.8
R-363	Participant	62.3	58.5	52.6	46.8	43.9	39.8	30.3	6.6	-68.4
R-369	Non-Participant	62.8	59.0	53.2	47.5	44.7	40.6	30.7	4.8	-75.8
R-382	Non-Participant	62.8	58.9	53.0	47.0	44.2	40.1	30.8	9.4	-58.4
R-387	Non-Participant	63.3	59.4	53.4	47.1	43.9	39.3	28.1	-1.4	-94.5
R-388	Non-Participant	63.9	60.1	54.2	48.3	45.5	41.3	31.3	6.0	-73.0
R-389	Non-Participant	63.6	59.8	53.9	48.0	45.1	41.0	31.4	7.5	-69.0
R-394	Non-Participant	64.0	60.1	54.1	47.9	44.8	40.7	31.8	10.7	-55.4
R-395	Participant	64.0	60.1	54.1	47.9	44.7	40.4	30.2	3.9	-79.4
R-396	Non-Participant	64.6	60.8	54.7	48.4	45.2	41.2	32.0	8.4	-66.5
R-397	Participant	64.0	60.2	54.1	47.8	44.5	40.0	29.2	0.0	-93.9
R-398	Non-Participant	63.2	59.3	53.2	46.9	43.6	39.1	29.0	4.7	-71.7
R-399	Non-Participant	63.5	59.6	53.6	47.6	44.6	40.5	30.9	6.9	-69.9
R-400	Non-Participant	63.6	59.8	53.9	48.0	45.1	40.8	30.7	3.9	-82.6
R-401	Participant	63.8	60.0	54.1	48.2	45.4	41.1	31.1	5.1	-78.0
R-408	Non-Participant	63.0	59.1	53.1	47.0	44.0	39.9	30.6	8.8	-59.9
R-409	Non-Participant	62.6	58.6	52.6	46.5	43.6	39.6	30.6	9.0	-59.3
R-417	Participant	61.7	57.9	51.9	46.0	43.4	40.1	32.4	12.8	-49.3
R-423	Non-Participant	62.9	59.0	53.1	47.2	44.5	40.6	32.2	11.8	-53.0
R-438	Non-Participant	63.7	59.8	54.0	48.2	45.4	41.4	32.6	12.8	-49.0
R-439	Non-Participant	63.8	59.9	54.0	48.1	45.3	41.3	32.3	10.1	-60.5
R-443	Non-Participant	62.3	58.4	52.6	46.7	43.8	39.7	30.2	6.2	-72.5
R-444	Non-Participant	62.3	58.5	52.6	46.7	43.9	39.9	30.7	8.4	-62.2
R-453	Non-Participant	61.9	58.0	52.2	46.5	43.8	39.9	30.3	4.9	-77.5
R-475	Participant	63.0	59.2	53.3	47.4	44.5	40.2	30.3	6.6	-68.2
R-484	Non-Participant	62.8	58.9	53.0	47.1	44.3	40.2	30.8	6.7	-71.7
R-498	Non-Participant	62.9	59.0	53.2	47.5	44.9	41.1	32.5	12.9	-48.9
R-500	Participant	63.5	59.6	53.7	47.7	44.6	40.1	29.4	1.8	-88.7
R-501	Non-Participant	64.0	60.2	54.2	48.0	44.9	40.9	32.0	9.4	-63.3
R-502	Non-Participant	63.8	59.9	54.0	48.1	45.1	40.7	30.3	4.0	-80.1
R-503	Non-Participant	63.9	60.1	54.3	48.4	45.5	41.2	31.1	5.6	-74.5
R-515	Participant	64.2	60.3	54.2	47.9	44.7	40.8	32.3	10.5	-61.2
R-582	Non-Participant	62.7	58.8	52.9	46.8	43.8	39.2	28.2	-0.6	-94.2
R-588	Non-Participant	63.7	59.8	53.9	47.9	44.9	40.5	29.8	0.4	-93.4
R-597	Non-Participant	62.6	58.7	52.8	46.8	44.0	40.1	31.4	9.5	-62.8
R-632	Participant	64.2	60.3	54.2	47.8	44.6	41.0	32.7	9.5	-68.8
R-748	Non-Participant	63.5	59.7	53.9	48.1	45.4	41.4	32.1	8.7	-63.4
R-754	Participant	63.5	59.7	53.7	47.6	44.6	40.9	32.3	9.1	-65.0
R-773	Participant	61.0	57.0	51.0	45.0	42.2	38.4	30.1	9.9	-56.7
SR-C6	Non-Participant	62.5	58.6	52.7	46.8	43.8	39.5	29.2	2.2	-84.7

**Pleasant Ridge Sound Analysis MAXIMUM Octave Bands Results Summary (GE 1.72-103 Turbine Model)  
Four LNTE Turbines and Substation (500 and 1000 Hz Bands)**

<i>With Substation</i>										
<i>All Values in dB</i>	<b>Octave Band Center Frequency</b>	<b>31.5 Hz</b>	<b>62.5 Hz</b>	<b>125 Hz</b>	<b>250 Hz</b>	<b>500 Hz *</b>	<b>1000 Hz *</b>	<b>2000 Hz</b>	<b>4000 Hz</b>	<b>8000 Hz</b>
<b>IPCB Daytime</b>		<b>75.0</b>	<b>74.0</b>	<b>69.0</b>	<b>64.0</b>	<b>58.0</b>	<b>52.0</b>	<b>47.0</b>	<b>43.0</b>	<b>40.0</b>
<b>IPCB Nighttime</b>		<b>69.0</b>	<b>67.0</b>	<b>62.0</b>	<b>54.0</b>	<b>47.0</b>	<b>41.0</b>	<b>36.0</b>	<b>32.0</b>	<b>32.0</b>
<b>Max Sound-dBA (Std Blade)</b>		<b>80.7</b>	<b>90.5</b>	<b>95.7</b>	<b>99.0</b>	<b>102.2</b>	<b>102.7</b>	<b>99.6</b>	<b>93.2</b>	<b>77.1</b>
<b>Max Sound dBA (LNTE Blade)</b>		<b>76.3</b>	<b>85.6</b>	<b>92.7</b>	<b>94.8</b>	<b>96.5</b>	<b>100.8</b>	<b>100.0</b>	<b>92.4</b>	<b>74.5</b>
<b>Reference ID</b>	<b>Participation Status and Results</b>									
R-005	Non-Participant	63.2	59.5	54.1	48.9	45.7	41.1	31.6	7.6	-71.0
R-006	Non-Participant	62.9	59.1	53.5	48.2	44.8	40.2	31.3	10.7	-54.7
R-007	Non-Participant	62.8	59.0	53.4	47.9	44.2	39.1	28.4	0.5	-89.9
R-008	Non-Participant	62.9	59.1	53.5	48.1	44.4	39.5	29.7	7.2	-64.3
R-009	Non-Participant	62.9	59.1	53.5	47.9	44.1	38.9	27.2	-3.1	-99.9
R-010	Non-Participant	63.0	59.2	53.6	48.1	44.3	39.1	27.7	-1.5	-94.5
R-011	Participant	63.2	59.4	53.9	48.5	44.9	40.1	30.1	5.7	-72.7
R-012	Non-Participant	63.1	59.3	53.7	48.3	44.7	40.3	31.0	5.9	-74.7
R-013	Participant	63.3	59.5	54.1	48.7	45.1	41.2	33.2	12.2	-54.3
R-014	Participant	63.0	59.2	53.7	48.3	44.6	40.3	31.3	6.3	-75.8
R-021	Non-Participant	63.0	59.2	53.6	48.2	44.6	39.7	29.9	7.8	-62.4
R-022	Participant	63.6	59.8	54.3	49.1	45.7	41.1	31.8	10.3	-56.6
R-023	Participant	62.8	59.0	53.4	47.9	44.3	39.2	29.2	6.3	-66.5
R-027	Non-Participant	62.3	58.6	53.3	47.9	44.8	39.7	30.1	8.3	-54.2
R-028	Participant	62.7	59.0	53.5	48.5	45.4	41.2	33.1	14.3	-45.5
R-038	Non-Participant	62.9	59.1	53.6	48.4	45.1	40.5	31.0	7.7	-68.1
R-039	Non-Participant	62.5	58.7	53.1	48.0	44.7	40.3	31.2	8.4	-66.9
R-041	Non-Participant	59.5	55.5	49.5	43.5	39.5	33.8	21.8	-9.5	-113.2
R-043	Non-Participant	60.5	56.6	50.9	45.6	42.3	38.1	30.1	11.0	-52.8
R-059	Participant	62.4	58.7	53.1	47.8	44.3	39.5	29.2	3.0	-81.8
R-060	Participant	63.2	59.5	54.0	48.9	45.7	41.4	32.9	13.1	-50.9
R-063	Non-Participant	62.4	58.6	53.0	47.8	44.3	39.4	29.8	7.9	-61.8
R-085	Non-Participant	62.4	58.7	53.0	47.7	44.2	39.5	30.1	8.3	-60.9
R-091	Participant	63.7	60.0	54.5	49.3	46.0	41.3	31.6	9.2	-60.4
R-092	Non-Participant	63.7	60.0	54.6	49.5	46.2	41.4	31.5	7.3	-67.6
R-093	Participant	62.5	58.7	53.1	47.9	44.4	39.6	29.7	5.6	-73.7
R-099	Non-Participant	62.6	58.8	53.2	47.6	43.8	39.0	28.7	4.5	-71.6
R-100	Non-Participant	62.6	58.8	53.2	47.7	44.0	39.2	29.6	8.2	-60.7
R-101	Non-Participant	62.9	59.1	53.5	48.2	44.6	39.8	29.9	5.8	-73.5
R-102	Non-Participant	63.2	59.4	53.9	48.6	45.2	40.8	31.9	11.0	-57.9
R-122	Participant	62.1	58.3	52.7	47.5	44.0	39.3	29.2	3.7	-79.9
R-142	Non-Participant	62.7	58.9	53.3	47.8	44.0	39.2	29.3	5.6	-68.8
R-160	Non-Participant	62.6	58.9	53.3	48.0	44.6	39.9	30.5	8.2	-61.6
R-166	Non-Participant	62.8	59.0	53.6	48.5	45.2	40.7	31.3	8.0	-68.0
R-168	Non-Participant	62.5	58.7	53.2	48.1	44.8	40.3	31.4	10.6	-56.1
R-169	Non-Participant	61.7	57.9	52.3	47.1	43.8	39.4	31.2	12.3	-49.6
R-183	Participant	62.2	58.4	52.8	47.6	44.2	39.6	30.8	11.2	-52.4
R-185	Participant	63.7	59.9	54.5	49.1	45.5	41.0	31.3	6.6	-70.7
R-186	Non-Participant	63.3	59.5	54.0	48.5	44.7	40.2	30.2	3.3	-82.1
R-187	Non-Participant	63.0	59.2	53.6	48.1	44.3	39.2	28.6	3.3	-75.6
R-191	Participant	62.8	59.1	53.5	48.2	44.8	40.3	31.7	11.0	-56.1
R-210	Non-Participant	62.5	58.8	53.2	47.9	44.5	39.7	29.5	4.6	-73.6
R-216	Non-Participant	62.2	58.5	53.1	48.2	45.2	41.3	33.3	13.2	-53.3
R-217	Participant	61.5	57.7	52.2	47.2	44.1	40.0	32.0	13.1	-47.6
R-221	Participant	62.7	58.9	53.4	48.2	44.9	40.3	31.0	9.2	-59.1
R-222	Non-Participant	62.7	59.0	53.4	48.3	44.9	40.2	30.8	9.3	-58.2
R-236	Non-Participant	62.5	58.7	53.2	48.0	44.7	40.1	31.6	13.3	-46.7
R-237	Participant	62.9	59.2	53.7	48.7	45.4	41.1	32.8	14.4	-44.2
R-239	Non-Participant	63.2	59.4	53.9	48.7	45.4	40.6	30.7	7.4	-64.4
R-240	Participant	63.2	59.5	54.0	48.8	45.4	40.7	31.0	9.3	-58.1
R-241	Non-Participant	63.4	59.7	54.2	49.0	45.7	41.1	31.7	9.2	-61.8
R-242	Non-Participant	63.2	59.4	53.9	48.7	45.3	40.5	30.4	5.0	-73.7
R-243	Non-Participant	63.3	59.5	54.0	48.9	45.6	41.1	32.1	10.7	-56.7
R-244	Participant	63.5	59.7	54.2	49.1	45.8	41.3	32.0	8.8	-66.5
R-270	Non-Participant	63.0	59.2	53.7	48.6	45.3	40.9	31.6	8.3	-64.7
R-311	Non-Participant	63.4	59.6	54.1	48.8	45.4	40.8	31.6	9.3	-64.3
R-313	Non-Participant	63.7	60.0	54.5	49.3	45.9	41.3	32.1	9.8	-61.5
R-314	Participant	63.7	60.0	54.6	49.4	46.1	41.3	31.4	6.6	-72.4
R-317	Non-Participant	63.3	59.5	54.0	48.7	45.2	40.3	30.0	5.6	-70.1
R-318	Non-Participant	62.9	59.1	53.5	48.1	44.4	39.3	28.6	3.6	-74.3

**Pleasant Ridge Sound Analysis MAXIMUM Octave Bands Results Summary (GE 1.72-103 Turbine Model)  
Four LNTE Turbines and Substation (500 and 1000 Hz Bands)**

<i>With Substation</i>										
<i>All Values in dB</i>	<b>Octave Band Center Frequency</b>	<b>31.5 Hz</b>	<b>62.5 Hz</b>	<b>125 Hz</b>	<b>250 Hz</b>	<b>500 Hz *</b>	<b>1000 Hz *</b>	<b>2000 Hz</b>	<b>4000 Hz</b>	<b>8000 Hz</b>
R-319	Non-Participant	63.1	59.3	53.7	48.4	44.8	39.8	29.1	2.7	-81.2
R-321	Non-Participant	62.8	59.1	53.5	48.2	44.9	40.5	31.9	11.5	-54.9
R-324	Participant	63.0	59.2	53.6	48.2	44.6	40.1	30.9	7.5	-64.5
R-326	Non-Participant	62.2	58.4	52.9	47.3	43.4	39.2	30.4	6.3	-69.1
R-327	Participant	63.4	59.6	54.1	48.8	45.3	40.7	31.1	7.1	-71.8
R-329	Non-Participant	63.1	59.3	54.0	48.4	44.5	41.1	34.0	14.3	-47.7
R-345	Non-Participant	63.5	59.8	54.3	49.1	45.7	41.1	31.9	10.1	-57.9
R-354	Participant	62.6	58.8	53.2	48.0	44.7	40.3	31.9	13.3	-46.9
R-355	Non-Participant	62.3	58.5	52.9	47.5	44.1	39.4	29.8	5.9	-72.6
R-363	Participant	61.9	58.2	52.6	47.5	44.2	39.6	30.4	7.9	-64.2
R-369	Non-Participant	62.4	58.7	53.2	48.2	45.0	40.5	30.8	6.1	-71.6
R-382	Non-Participant	62.3	58.6	53.0	47.8	44.4	39.9	30.9	10.7	-54.2
R-387	Non-Participant	62.8	59.0	53.4	48.0	44.3	39.2	28.2	-0.1	-90.3
R-388	Non-Participant	63.5	59.8	54.3	49.1	45.8	41.1	31.4	7.3	-68.8
R-389	Non-Participant	63.2	59.5	53.9	48.7	45.4	40.8	31.5	8.8	-64.8
R-394	Non-Participant	63.2	59.4	53.9	48.5	44.9	40.6	32.0	11.9	-51.2
R-395	Participant	63.3	59.5	54.0	48.5	44.9	40.3	30.3	5.1	-75.2
R-396	Non-Participant	63.6	59.8	54.4	49.0	45.3	41.1	32.3	9.2	-62.7
R-397	Participant	63.2	59.4	53.9	48.4	44.6	39.9	29.4	0.8	-90.2
R-398	Non-Participant	62.5	58.7	53.1	47.6	43.8	39.0	29.1	5.9	-67.5
R-399	Non-Participant	62.9	59.2	53.6	48.3	44.9	40.3	31.0	8.2	-65.7
R-400	Non-Participant	63.2	59.5	53.9	48.7	45.3	40.7	30.8	5.2	-78.4
R-401	Participant	63.4	59.6	54.1	49.0	45.6	40.9	31.2	6.4	-73.8
R-408	Non-Participant	62.5	58.7	53.1	47.8	44.3	39.7	30.7	10.1	-55.7
R-409	Non-Participant	62.1	58.3	52.6	47.3	43.9	39.4	30.7	10.3	-55.1
R-417	Participant	61.4	57.6	52.1	47.2	44.3	40.3	32.5	14.0	-45.1
R-423	Non-Participant	62.4	58.7	53.1	47.9	44.7	40.5	32.3	13.1	-48.8
R-438	Non-Participant	63.2	59.5	54.0	48.9	45.7	41.2	32.7	14.1	-44.8
R-439	Non-Participant	63.3	59.6	54.1	49.0	45.8	41.3	32.4	11.4	-56.3
R-443	Non-Participant	61.9	58.1	52.6	47.4	44.0	39.5	30.3	7.5	-68.3
R-444	Non-Participant	61.9	58.2	52.6	47.4	44.1	39.7	30.8	9.7	-58.0
R-453	Non-Participant	61.5	57.7	52.2	47.2	44.0	39.7	30.4	6.2	-73.3
R-475	Participant	62.6	58.9	53.3	48.1	44.7	40.0	30.4	7.9	-64.0
R-484	Non-Participant	62.3	58.6	53.0	47.9	44.5	40.0	30.9	8.0	-67.5
R-498	Non-Participant	62.4	58.7	53.2	48.2	45.1	40.9	32.6	14.2	-44.7
R-500	Participant	63.1	59.3	53.7	48.4	44.9	39.9	29.5	3.1	-84.5
R-501	Non-Participant	63.6	59.9	54.4	49.3	46.0	41.3	32.0	10.2	-59.8
R-502	Non-Participant	63.3	59.6	54.1	48.9	45.4	40.6	30.4	5.3	-75.9
R-503	Non-Participant	63.5	59.8	54.3	49.1	45.8	41.0	31.2	6.9	-70.3
R-515	Participant	63.2	59.4	53.9	48.4	44.7	40.7	32.6	10.8	-59.3
R-582	Non-Participant	62.3	58.5	52.9	47.5	44.0	39.0	28.3	0.7	-90.0
R-588	Non-Participant	63.3	59.5	54.0	48.7	45.3	40.4	29.9	1.7	-89.2
R-597	Non-Participant	62.2	58.4	52.8	47.6	44.3	39.9	31.5	10.8	-58.6
R-632	Participant	63.4	59.6	54.2	48.9	45.4	41.3	32.9	10.0	-65.8
R-748	Non-Participant	63.1	59.4	53.9	48.8	45.6	41.2	32.2	10.0	-59.2
R-754	Participant	63.2	59.4	54.0	48.9	45.7	41.3	32.3	9.9	-61.5
R-773	Participant	60.6	56.7	51.0	45.7	42.4	38.2	30.2	11.2	-52.5
SR-C6	Non-Participant	62.1	58.3	52.7	47.5	44.1	39.3	29.3	3.5	-80.5

100m Blade		Octave Band Center Frequency (Hertz)								
16-Jan-15		31	63	125	250	500	1000	2000	4000	8000
Receptor	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)
1	5	63.6	59.8	53.8	47.8	44.9	40.9	31.5	6.5	-75.1
2	6	63.3	59.5	53.5	47.4	44.4	40.3	31.2	9.4	-58.9
3	7	63.3	59.4	53.3	46.9	43.6	39.0	28.3	-0.8	-94.1
4	8	63.4	59.5	53.5	47.2	44.1	39.6	29.6	5.9	-68.5
5	9	63.5	59.6	53.4	46.9	43.4	38.6	27.1	-3.9	-103.3
6	10	63.6	59.7	53.5	47.0	43.5	38.8	27.7	-2.3	-97.9
7	11	63.8	59.9	53.8	47.6	44.5	40.2	30.0	4.4	-76.9
8	12	63.8	59.9	53.7	47.1	43.7	39.9	30.9	5.3	-78.0
9	13	64.3	60.4	54.1	47.3	43.7	40.4	33.0	12.0	-57.2
10	14	63.8	59.9	53.7	47.1	43.7	39.9	31.1	5.8	-78.1
11	21	63.4	59.5	53.3	46.7	43.2	38.9	29.9	7.3	-65.8
12	22	64.0	60.1	54.0	47.6	44.3	40.4	31.8	9.7	60.0
13	23	63.2	59.3	53.3	47.0	43.7	39.2	29.1	5.0	70.7
14	27	62.7	58.8	53.0	46.8	44.0	39.4	29.8	6.8	55.8
15	28	63.1	59.2	53.1	46.6	43.4	40.3	33.1	13.7	48.9
16	38	63.3	59.4	53.2	46.9	43.7	40.0	30.9	6.7	-72.0
17	39	62.8	59.0	52.9	46.8	43.8	40.0	31.1	7.2	-71.1
18	41	59.9	55.8	49.3	42.3	38.6	33.6	21.7	-10.8	-117.4
19	43	60.9	56.9	50.8	44.8	42.0	38.3	30.0	9.7	-57.0
20	59	62.8	58.9	52.8	46.3	43.0	38.9	29.1	2.2	-85.3
21	60	63.6	59.7	53.7	47.5	44.5	40.9	32.8	12.0	-55.0
22	63	62.8	58.9	52.8	46.7	43.6	39.4	29.7	6.6	-66.0
23	85	62.9	59.0	52.8	46.6	43.5	39.4	30.0	7.0	-65.1
24	91	64.1	60.3	54.1	47.7	44.4	40.5	31.6	8.5	-63.8
25	92	64.1	60.3	54.3	48.1	45.1	41.0	31.5	6.3	-71.8
26	93	62.9	59.0	53.1	47.0	44.0	39.7	29.6	4.3	-77.9
27	99	63.3	59.4	53.2	46.8	43.5	39.1	28.6	3.2	-75.8
28	100	63.2	59.3	53.2	46.9	43.7	39.3	29.5	6.9	-64.9
29	101	63.4	59.5	53.4	46.9	43.6	39.4	29.9	4.9	-77.3
30	102	63.7	59.8	53.8	47.8	44.8	40.8	31.8	9.7	-62.1
31	122	62.5	58.6	52.6	46.5	43.5	39.2	29.1	2.4	-84.1
32	142	63.4	59.4	53.3	46.8	43.5	39.2	29.2	4.3	-73.0
33	160	63.0	59.1	53.1	46.9	43.8	39.8	30.4	6.9	-65.8
34	166	63.2	59.3	53.5	47.7	44.9	40.8	31.2	6.7	-72.2
35	168	62.9	59.0	53.2	47.3	44.5	40.5	31.3	9.3	-60.3
36	169	62.1	58.2	52.3	46.3	43.5	39.6	31.1	11.0	-53.8
37	183	62.6	58.8	52.8	46.7	43.8	39.8	30.7	9.9	-56.6
38	185	64.4	60.6	54.5	48.3	45.1	41.0	31.1	5.4	-74.9
39	186	64.2	60.3	54.1	47.6	44.2	40.0	30.0	3.0	-83.5
40	187	63.5	59.6	53.5	47.3	44.0	39.4	28.5	2.0	-79.8
41	191	63.4	59.5	53.5	47.4	44.5	40.5	31.6	9.7	-60.3
42	210	62.9	59.1	53.1	47.0	44.1	39.7	29.4	3.3	-77.8
43	216	62.6	58.7	52.7	46.6	43.9	40.8	33.2	12.2	-57.1
44	217	61.9	58.0	52.0	46.0	43.3	39.9	31.9	11.8	-51.8
45	221	63.1	59.2	53.0	46.6	43.3	39.5	30.9	8.6	-62.5
46	222	63.1	59.2	53.2	47.0	44.0	40.0	30.7	8.0	-62.4
47	236	62.9	59.0	53.1	47.1	44.3	40.2	31.5	12.0	-50.9
48	237	63.3	59.4	53.2	46.7	43.3	40.0	32.8	13.9	-47.6
49	239	63.6	59.7	53.8	47.7	44.7	40.6	30.6	6.1	-68.6
50	240	63.6	59.8	53.8	47.7	44.7	40.6	30.9	8.0	-62.3
51	242	63.8	59.9	54.0	47.9	44.9	41.0	31.8	8.0	-66.0
52	242	63.6	59.7	53.7	47.5	44.4	40.3	30.3	3.8	-77.9
53	243	63.7	59.8	53.8	47.6	44.6	40.8	32.1	9.6	-60.9
54	244	63.9	60.0	54.0	47.8	44.7	40.9	32.0	7.9	-70.1
55	270	63.4	59.5	53.4	47.1	44.0	40.3	31.5	7.6	-68.1
56	311	63.8	59.9	54.0	47.9	45.0	40.9	31.5	8.0	-68.5
57	313	64.1	60.2	54.2	47.9	44.8	40.9	32.0	8.8	-65.6
58	314	64.1	60.2	54.2	47.9	44.9	40.8	31.3	5.6	-76.5
59	317	63.7	59.8	53.6	47.0	43.6	39.4	30.0	5.1	-73.5
60	318	63.3	59.4	53.3	46.9	43.6	39.1	28.5	2.3	-78.5
61	319	63.5	59.6	53.5	47.1	43.8	39.4	29.1	1.6	-85.4
62	321	63.3	59.4	53.4	47.3	44.4	40.6	31.8	10.2	-59.1
63	324	63.7	59.8	53.5	46.8	43.3	39.5	30.8	7.0	-67.9
64	326	63.2	59.3	53.0	46.4	42.9	39.0	30.2	6.3	-69.9
65	327	64.1	60.2	54.2	48.0	45.0	40.8	31.0	5.8	-76.0
66	329	64.5	60.6	54.2	47.1	43.3	40.3	33.7	14.4	-48.7
67	345	64.0	60.1	54.1	48.0	44.9	40.9	31.8	8.9	-62.1
68	354	63.0	59.1	53.1	47.1	44.3	40.5	31.8	12.0	-51.1
69	355	62.7	58.8	52.8	46.6	43.7	39.5	29.7	4.6	-76.8
70	363	62.3	58.5	52.6	46.7	43.9	39.8	30.3	6.6	-68.4
71	369	62.8	59.0	53.2	47.5	44.7	40.6	30.7	4.8	-75.8
72	382	62.8	58.9	52.9	46.9	44.0	40.0	30.8	9.4	-58.4
73	387	63.3	59.4	53.2	46.8	43.5	39.0	28.1	-1.3	-94.4
74	388	63.9	60.1	54.0	47.8	44.7	40.8	31.4	6.5	-72.2
75	389	63.6	59.8	53.8	47.7	44.7	40.8	31.4	7.5	-69.0
76	394	64.0	60.1	54.0	47.6	44.4	40.6	31.8	10.7	-55.4
77	395	64.0	60.1	54.0	47.5	44.2	40.1	30.2	3.9	-79.4
78	396	64.6	60.7	54.5	47.8	44.2	40.5	32.1	8.9	-65.8
79	397	64.0	60.2	54.0	47.6	44.2	39.8	29.2	0.0	-93.9
80	398	63.2	59.3	53.2	46.8	43.5	39.1	29.0	4.7	-71.7
81	399	63.4	59.6	53.6	47.5	44.6	40.4	30.9	6.9	-69.9
82	400	63.6	59.8	53.8	47.6	44.5	40.5	30.7	4.2	-82.5
83	401	63.8	59.9	53.9	47.8	44.7	40.7	31.1	5.4	-77.6
84	408	63.0	59.1	53.1	47.0	44.0	39.9	30.6	8.8	-59.9
85	409	62.6	58.6	52.6	46.5	43.6	39.6	30.6	9.0	-59.3
86	417	61.7	57.9	51.9	46.0	43.4	40.1	32.4	12.8	-49.3
87	423	62.9	59.0	53.0	47.1	44.4	40.6	32.2	11.8	-53.0
88	438	63.6	59.8	53.8	47.6	44.7	41.0	32.6	12.8	-49.0
89	439	63.7	59.9	53.7	47.3	44.1	40.5	32.3	10.7	-59.8
90	443	62.3	58.4	52.4	46.4	43.5	39.5	30.2	6.2	-72.5
91	444	62.3	58.4	52.5	46.5	43.6	39.7	30.7	8.4	-62.2
92	453	61.9	58.0	52.2	46.5	43.8	39.9	30.3	4.9	-77.5
93	475	63.0	59.2	53.2	47.2	44.3	40.1	30.3	6.6	-68.2
94	484	62.8	58.9	52.9	46.9	44.1	40.1	30.8	6.7	-71.7
95	498	62.8	58.9	52.7	46.2	42.9	39.7	32.6	13.6	-48.1
96	500	63.5	59.6	53.5	47.2	44.0	39.6	29.5	2.1	-88.2
97	501	64.0	60.2	54.1	47.9	44.7	40.8	32.0	9.4	-63.3
98	502	63.7	59.9	53.9	47.7	44.6	40.4	30.4	4.1	-80.1
99	503	63.9	60.1	54.0	47.8	44.7	40.7	31.1	6.1	-73.7
100	515	64.2	60.3	54.1	47.5	44.2	40.5	32.4	10.5	-61.2
101	582	62.7	58.8	52.8	46.6	43.6	39.1	28.2	-0.6	-94.2
102	588	63.7	59.8	53.8	47.5	44.4	40.2	29.8	0.8	-92.7
103	597	62.6	58.7	52.7	46.7	43.9	40.1	31.4	9.5	-62.8
104	632	64.2	60.3	54.2	47.8	44.5	41.0	32.7	9.5	-68.8
105	748	63.5	59.6	53.5	47.3	44.2	40.6	32.2	9.3	-62.6
106	754	63.5	59.7	53.7	47.5	44.5	40.9	32.3	9.1	-65.0
107	773	61.0	57.0	50.9	44.9	42.1	38.4	30.1	9.9	-56.7
108	SR-C6	62.5	58.6	52.5	46.4	43.4	39.2	29.2	2.3	-84.7

103m Blade		Octave Band Center Frequency (Hertz)							
16-Jan-15	31	63	125	250	500	1000	2000	4000	8000
Receptor	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)
1	5	63.0	59.2	53.9	48.8	45.5	41.0	31.6	7.6
2	6	62.7	58.9	53.4	48.1	44.6	40.2	31.3	10.7
3	7	62.5	58.7	53.1	47.6	43.8	38.9	28.4	0.5
4	8	62.7	58.9	53.3	47.9	44.2	39.4	29.7	7.2
5	9	62.5	58.6	53.1	47.5	43.4	38.5	27.4	-3.6
6	10	62.5	58.7	53.2	47.5	43.6	38.7	27.9	-1.9
7	11	63.0	59.2	53.7	48.2	44.6	40.0	30.1	5.7
8	12	62.4	58.6	53.2	47.6	43.7	39.8	31.2	5.5
9	13	62.4	58.5	53.4	47.6	43.5	40.5	33.3	11.7
10	14	62.4	58.5	53.2	47.6	43.7	39.9	31.4	6.0
11	21	62.2	58.3	52.9	47.2	43.2	38.9	30.2	7.0
12	22	62.8	59.0	53.7	48.2	44.4	40.4	32.1	9.7
13	23	62.4	58.6	53.1	47.6	43.9	39.1	29.2	6.3
14	27	62.0	58.3	53.0	47.7	44.6	39.7	30.1	8.3
15	28	62.0	58.2	53.0	47.8	44.5	40.8	33.2	14.2
16	38	62.3	58.5	53.1	47.8	44.3	40.2	31.1	7.6
17	39	61.8	58.0	52.6	47.3	43.8	39.9	31.3	8.4
18	41	59.0	55.0	49.0	42.9	38.7	33.5	21.9	9.5
19	43	60.3	56.4	50.8	45.5	42.2	38.1	30.1	11.0
20	59	61.7	57.8	52.4	46.9	43.1	38.8	29.4	2.5
21	60	62.4	58.6	53.3	48.0	44.5	40.8	33.0	12.9
22	63	62.0	58.2	52.7	47.3	43.8	39.2	29.8	7.9
23	85	61.9	58.1	52.6	47.2	43.6	39.2	30.1	8.3
24	91	62.8	59.0	53.8	48.3	44.6	40.6	31.8	8.5
25	92	63.1	59.3	54.1	48.8	45.3	41.0	31.6	7.2
26	93	61.7	57.9	52.5	47.0	43.3	39.0	29.9	5.3
27	99	62.4	58.5	53.0	47.4	43.6	38.9	28.7	4.5
28	100	62.4	58.6	53.0	47.5	43.8	39.2	29.6	8.2
29	101	62.3	58.5	53.1	47.5	43.7	39.3	30.1	5.4
30	102	62.9	59.2	53.7	48.4	45.0	40.6	31.9	11.0
31	122	61.9	58.1	52.6	47.4	44.0	39.2	29.2	3.7
32	142	62.3	58.5	53.0	47.4	43.6	39.1	29.4	5.6
33	160	62.2	58.4	52.9	47.5	44.0	39.7	30.5	8.1
34	166	62.7	58.9	53.5	48.4	45.1	40.7	31.3	8.0
35	168	62.3	58.6	53.1	48.0	44.7	40.3	31.4	10.6
36	169	61.5	57.7	52.2	47.0	43.7	39.4	31.2	12.3
37	183	61.8	58.0	52.5	47.2	43.8	39.5	30.9	11.2
38	185	63.4	59.6	54.3	48.9	45.2	40.9	31.3	6.6
39	186	62.9	59.1	53.7	48.1	44.2	39.9	30.3	3.2
40	187	62.7	58.9	53.4	47.9	44.2	39.2	28.6	3.3
41	191	62.7	58.9	53.4	48.1	44.7	40.3	31.7	11.0
42	210	61.9	58.0	52.7	47.2	43.6	39.2	29.6	4.5
43	216	61.2	57.3	52.2	47.0	43.8	40.7	33.5	12.8
44	217	59.9	55.9	50.8	45.2	41.3	38.8	32.3	12.3
45	221	62.2	58.4	53.0	47.7	44.2	39.9	31.0	9.2
46	222	61.8	57.9	52.6	47.1	43.3	39.4	31.1	8.5
47	236	62.3	58.5	53.1	47.9	44.5	40.1	31.6	13.3
48	237	62.7	59.0	53.6	48.5	45.3	41.0	32.8	14.4
49	239	62.8	59.0	53.6	48.4	45.0	40.5	30.7	7.4
50	240	62.8	59.0	53.7	48.4	45.0	40.5	31.1	9.3
51	241	62.9	59.1	53.8	48.5	45.1	40.6	31.8	9.2
52	242	62.6	58.8	53.4	48.1	44.5	40.1	30.4	4.9
53	243	62.6	58.8	53.5	48.2	44.7	40.7	32.2	10.5
54	244	62.7	58.9	53.7	48.3	44.8	40.8	32.2	8.5
55	270	62.1	58.2	53.0	47.5	44.0	40.2	31.8	7.7
56	311	63.1	59.3	53.9	48.6	45.2	40.7	31.6	9.3
57	313	63.0	59.2	53.9	48.5	44.9	40.8	32.2	9.6
58	314	63.1	59.3	54.1	48.7	45.3	40.9	31.4	6.4
59	317	62.3	58.5	53.2	47.6	43.6	39.4	30.3	4.8
60	318	62.4	58.5	53.1	47.6	43.8	39.0	28.6	3.6
61	319	62.5	58.7	53.3	47.8	44.0	39.4	29.2	2.6
62	321	62.6	58.9	53.3	48.1	44.8	40.5	31.9	11.5
63	324	62.2	58.3	53.0	47.2	43.2	39.5	31.1	6.8
64	326	61.8	58.0	52.6	46.9	42.9	39.0	30.5	6.3
65	327	63.2	59.4	54.0	48.6	45.1	40.6	31.1	7.1
66	329	62.2	58.2	53.2	47.2	42.8	40.5	34.1	14.1
67	345	63.1	59.3	53.9	48.6	45.1	40.8	32.0	10.0
68	354	62.3	58.6	53.0	47.8	44.5	40.3	31.9	13.3
69	355	62.0	58.2	52.7	47.3	43.9	39.3	29.8	5.9
70	363	61.8	58.1	52.6	47.4	44.1	39.6	30.4	7.9
71	369	62.3	58.6	53.2	48.2	44.9	40.4	30.8	6.1
72	382	61.7	57.9	52.5	47.2	43.7	39.6	31.0	10.6
73	387	62.5	58.7	53.2	47.7	44.0	39.1	28.2	-0.1
74	388	63.2	59.5	54.0	48.8	45.5	41.0	31.5	7.3
75	389	62.9	59.2	53.7	48.5	45.2	40.8	31.5	8.8
76	394	62.8	59.0	53.6	48.1	44.5	40.4	32.0	11.9
77	395	62.8	59.0	53.6	48.0	44.3	40.0	30.4	5.1
78	396	62.9	59.0	53.8	48.1	44.0	40.5	32.4	8.7
79	397	62.9	59.1	53.7	48.1	44.2	39.7	29.4	0.8
80	398	62.3	58.5	53.0	47.5	43.7	38.9	29.1	5.9
81	399	62.8	59.0	53.5	48.2	44.8	40.3	31.0	8.2
82	400	63.1	59.3	53.9	48.7	45.3	40.6	30.8	5.2
83	401	63.2	59.5	54.1	48.9	45.5	40.9	31.2	6.4
84	408	62.3	58.5	53.0	47.6	44.2	39.7	30.7	10.1
85	409	61.9	58.1	52.5	47.2	43.8	39.4	30.7	10.3
86	417	61.0	57.3	51.9	47.0	44.0	40.2	32.5	14.0
87	423	62.2	58.4	52.9	47.7	44.5	40.4	32.3	13.1
88	438	62.8	59.0	53.6	48.4	45.1	41.0	32.7	14.1
89	439	62.3	58.5	53.3	47.8	44.1	40.5	32.6	10.9
90	443	61.7	58.0	52.5	47.3	44.0	39.5	30.3	7.5
91	444	61.8	58.0	52.5	47.3	44.0	39.6	30.8	9.7
92	453	61.4	57.7	52.2	47.2	44.0	39.7	30.4	6.2
93	475	62.5	58.7	53.2	48.0	44.6	40.0	30.4	7.9
94	484	62.2	58.5	53.0	47.8	44.5	40.0	30.9	8.0
95	498	62.4	58.6	53.2	48.2	45.1	40.9	32.6	14.2
96	500	62.5	58.7	53.3	47.8	44.1	39.5	29.7	2.8
97	501	62.9	59.1	53.9	48.5	44.8	40.7	32.2	9.7
98	502	63.1	59.3	53.9	48.7	45.2	40.5	30.4	5.3
99	503	63.3	59.6	54.2	49.0	45.6	41.0	31.2	6.9
100	515	62.7	58.8	53.6	48.0	44.1	40.5	32.6	10.8
101	582	61.5	57.7	52.3	46.8	43.0	38.5	28.5	0.5
102	588	62.8	59.0	53.6	48.3	44.7	40.2	29.9	1.7
103	597	61.9	58.1	52.6	47.4	44.1	39.9	31.5	10.8
104	632	62.8	58.9	53.7	48.2	44.5	40.9	33.0	9.8
105	748	62.2	58.3	53.1	47.7	44.1	40.5	32.4	9.5
106	754	62.4	58.6	53.4	48.1	44.6	40.8	32.5	9.5
107	773	60.3	56.5	50.9	45.6	42.3	38.2	30.2	11.2
108	SR-C6	61.9	58.1	52.6	47.4	44.0	39.3	29.3	3.5

	Octave Band Center Frequency (Hz)								
	31 <u>(dB)</u>	63 <u>(dB)</u>	125 <u>(dB)</u>	250 <u>(dB)</u>	500 <u>(dB)</u>	1000 <u>(dB)</u>	2000 <u>(dB)</u>	4000 <u>(dB)</u>	8000 <u>(dB)</u>
GE 1.7-100	120	116	111	107	105	102	97	91	74
GE 1.7-100, LNTE	120	116	110	104	101	100	98	92	75
LNTE Reduction	0	0	1	3	4	2	-1	-1	-1
GE 1.7-103	120	117	112	107	105	102	98	92	76
GE 1.7-103, LNTE	116	112	109	103	100	100	99	91	75
LNTE Reduction	4	5	3	3	5	2	-1	0	1