


**PRELIMINARY**

**NOTES**  
 1. NET ENERGY INSTALLED ON SYSTEM SHALL BE 34.5 KV, 1200 A. SW345-8 TO PREVENT PARALLEL OPERATION OF TRANSFORMERS I1 AND I2.

ENGINEERING RECORD	DATE
DRAWN: DALRYMPLE	11/7/21
DESIGNED: SCHMITZ	11/7/21
CHECKED: SINGHAR	11/7/21
APPROVED: BAYDRESS	11/7/21
DATE SCALE	1:1

**LIVINGSTON PROJECT**  
**34.5 - 345 KV SUBSTATION**  
**SIMPLIFIED ONE LINE DIAGRAM SHEET 1**

NO.	REVISION	DATE	BY	APP.
A	PRELIMINARY			



FILE LOCATION: L:\EED\RENEWABLES\345KV LIVINGSTON SUBSTATION\100 CAD\100 CONCEPTUAL\345-P-5000-4\DWG LAST SAVED BY: J. WILSON 11/27/2021 3:57 PM REV: LVP-P-5000-4

**TECI ELECTRICAL CONSULTANTS, INC.**  
*Engineering with Distinction*